



GHASSAN EL-HOSS
ZETA ALARMS LTD
DETECTION HOUSE
72-78 MOREFA RD, HAFOD
SWANSEA
SA1 2EN UNITED KINGDOM

Date: 2018/09/03
Subscriber: None
PartySite:
File No:
Order No: 12368716
Project Number: 18OR12368716
PD No: 18039848
PO Number:

Subject: Multiple Listing Correlation Sheet

Dear Ghassan El-Hoss,

Enclosed is a copy of your completed Multiple Listing Correlation Sheet covering the Basic File listed below. The following documents were added (new) or revised on 08/15/2018.

<u>Basic File</u>	<u>Vol</u>	<u>ML File</u>	<u>Pages</u>	<u>Revised</u>	<u>New</u>
S25094	11	S36085	ML Cert of Compliance		

Please review this material and report any inaccuracies to UL's Customer Service Professionals. Contact information for all of UL's global offices can be found at <http://ul.com/aboutul/locations>.

If you'd like to receive updated materials FASTER, UL offers electronic access and/or delivery of this material. For more details, contact UL's Customer Service Professionals as shown above, referring to the above Order number.

This material is provided on behalf of UL LLC (UL) or any authorized licensee of UL.

NWT File

CERTIFICATE OF COMPLIANCE

Certificate Number 20180820-S36085
Report Reference S36085-20180815
Issue Date 2018-August-20

Issued to: ZETA ALARMS LTD
Detection House
72-78 Morfa Rd
Hafod, Swansea, GB SA1 2EN
United Kingdom

**This is to certify that
representative samples of**

SMOKE-AUTOMATIC FIRE DETECTORS; HEAT-
AUTOMATIC FIRE DETECTORS

Fire Alarm Subassembly:
Photoelectric, analog addressable, Smoke/Heat detector
head, Model VDOT-DPH with 135 °F (57 °C) fixed
temperature and 15 °F (8.3 °C) Rate of Rise temperature
thermistor.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


ANSI/UL 268 - SAFETY FOR SMOKE DETECTORS FOR
FIRE ALARM SYSTEMS.
ANSI/UL 521 - SAFETY FOR HEAT DETECTORS FOR
FIRE PROTECTIVE SIGNALING SYSTEMS.

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

